

# DISTRICT WATER TESTING LABORATORY, GURDASPUR

District Water Testing Laboratory, Jewanwal Babri, Gurdaspur  
dwtlgsp1@gmail.com

To,

Saint Soldier Modern Sr.Sec.School  
D.B.N Road Gurdaspur

No.: DWTLGSP/2526/00037      Dated : 30/04/2025

Subject :      Testing Reports of Water Samples.

Reference:      Your Letter/SRF No. SSMS/25/w-1      Dated: 28/04/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 28/04/2025. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Gurdaspur

D/A :      Test Report.



Authorized Signatory  
For, District Water Testing Laboratory  
Gurdaspur

# DISTRICT WATER TESTING LABORATORY, GURDASPUR

District Water Testing Laboratory, Jewanwal Babri, Gurdaspur  
dwtlgspl@gmail.com



TC-14032

## TEST REPORT

Name & Address of Customer : <b>Saint Soldier Modern Sr.Sec.School D.B.N Road Gurdaspur</b>		Customer Reference No.	No : SSMS/25/w-1 Dated : 28/04/2025
		Sample Submitted by	Principal
		Date of Sample Receipt	28/04/2025
		Analysis Starting Date	28/04/2025
		Analysis completion Date	30/04/2025
Discipline : <b>Chemical Testing</b>		Group: <b>Water</b>	
ULR No.:	TC140322500000225F	Sample Type :	Water
Test Report No.:	DWTLGSP/2526/00037	Date of Issue :	30/04/2025
Registration no.:	DWTLGSP/REG2526/00080	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Saint Soldier Modern Sr.Sec.School D.B.N. Road Gurdaspur / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Gurdaspur
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.2@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	270	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO <sub>3</sub> )	120	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO <sub>3</sub> )	136	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	24.05	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	18.47	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	13.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

- This Report is issued under the following terms & Condition :
1. The results apply to the sample as received only.
  2. The sample will be destroyed after retention time unless otherwise specified specially.
  3. This report is not to be reproduce wholly or in part and can't be used be as evidence in court of law.
  4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
  5. \* Value not available or test not performed for this parameter.
  6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr. Pankaj Kumar  
Quality Manager  
Authorized Signatory  
For, District Water Testing Laboratory  
Gurdaspur

End of the Test Report

# DISTRICT WATER TESTING LABORATORY, GURDASPUR

District Water Testing Laboratory, Jewanwal Babri, Gurdaspur  
dwtlgspl@gmail.com



TC-14032

## TEST REPORT

Name & Address of Customer : <b>Saint Soldier Modern Sr.Sec.School</b> <b>D.B.N Road Gurdaspur</b>		Customer Reference No.	No : SSMS/25/w-1 Dated : 28/04/2025
		Sample Submitted by	Principal
		Date of Sample Receipt	28/04/2025
		Analysis Starting Date	28/04/2025
		Analysis completion Date	30/04/2025
Discipline : <b>Chemical Testing</b>		Group: <b>Water</b>	
ULR No.:	TC14032250000225F	Sample Type :	Water
Test Report No.:	DWTLGSP/2526/00037	Date of Issue :	30/04/2025
Registration no.:	DWTLGSP/REG2526/00080	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Saint Soldier Modern Sr.Sec.School D.B.N. Road Gurdaspur / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Gurdaspur
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.2@25°C	6.5-8.5	No Relaxation	-	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	-	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	-	IS 3025 (Part 8 – 2023)
5	TDS	270	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	120	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	136	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	24.05	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	18.47	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	13.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

*(Signature)*

**Mr. Pankaj Kumar**  
 Quality Manager  
 Authorized Signatory  
 For, District Water Testing Laboratory  
 Gurdaspur

End of the Test Report